



Appliance Manufacturer:

Appliance Type:

Model Number:

Submitted by: **Date**

Approved by: **Date**

introduction

< APPLICABLE STANDARDS >

ULC S636
Standard for Type BH
Gas Venting systems

< LISTED BY >



System 636® CPVC Flue Gas Venting System is third party certified and listed to ULC S636 in accordance with the CSA B149.1 Natural Gas and Propane Installation Code. System 636 CPVC is intended for negative or positive pressure venting and is classified as a "Type BH Class II B 90°C" flue gas vent. System 636 PVC Pipe is grey in colour and is made to SCH 40 dimensions. Each length of vent pipe is uniquely marked with a dual print line and each length includes a special orange warning label in accordance with ULC S636. Every CPVC vent fitting, also grey in colour, has a warning label indicating its vent class and maximum temperature rating. System 636 CPVC has specially certified Cements and Primers which are an integral part of the "system certification" of the product line. Substitutions shall not be made for any component of a System 636 CPVC system, this includes pipe, fittings, cements and primers. Substitution of a component will void product warranty and ULC S636 system certification. System 636 venting shall be installed in accordance with the certified System 636 Installation Guide, and in accordance with the appliance manufacturer's installation instructions. In the event of conflicting installation instructions between the appliance manufacturer, the System 636 installation guide and/or Code requirements, the most restrictive requirement shall apply.

Products manufactured by IPEX Inc.
System 636® is a trademark of IPEX Branding Inc.

Canada: Website: www.ipexinc.com • Toll Free: 866-473-9462



IPEX

Pipe and Fittings submitted for approval.

<input type="checkbox"/>	198003	1-1/2	
<input type="checkbox"/>	198001	2	
<input type="checkbox"/>	198004	2-1/2	CPVC Gas Vent Pipe plain end (10 ft. lengths)
<input type="checkbox"/>	198000	3	
<input type="checkbox"/>	198002	4	
<input type="checkbox"/>	198005	6	CPVC Large Diameter Gas Vent Pipe plain end (10 ft. lengths)
<input type="checkbox"/>	198006	8	
<input type="checkbox"/>	197169	2	
<input type="checkbox"/>	197171	3	CPVC – FGV 45° Elbow H x H
<input type="checkbox"/>	197172	4	
<input type="checkbox"/>	197173	6	CPVC Large Diameter – FGV 45° Elbow H x H
<input type="checkbox"/>	197174	8	
<input type="checkbox"/>	197199	2	
<input type="checkbox"/>	197201	3	CPVC – FGV 90° Elbow H x H
<input type="checkbox"/>	197202	4	
<input type="checkbox"/>	197203	6	CPVC Large Diameter – FGV 90° Elbow H x H
<input type="checkbox"/>	197204	8	
<input type="checkbox"/>	197122	2	
<input type="checkbox"/>	197123	3	CPVC – FGV 90° Long Elbow H x H
<input type="checkbox"/>	197124	4	
<input type="checkbox"/>	197125	6	CPVC Large Diameter – FGV 90° Long Elbow H x H
<input type="checkbox"/>	197126	8	
<input type="checkbox"/>	197486	2	
<input type="checkbox"/>	197488	3	CPVC – FGV Tee H x H
<input type="checkbox"/>	197489	4	
<input type="checkbox"/>	197490	6	CPVC Large Diameter– FGV Tee H x H
<input type="checkbox"/>	197491	8	
<input type="checkbox"/>	197502	3 x 2	CPVC – FGV Reducer Tee H x H x H
<input type="checkbox"/>	197504	4 x 2	
<input type="checkbox"/>	197506	6 x 6 x 4	CPVC Large Diameter – FGV Reducer Tee H x H x H
<input type="checkbox"/>	197567	8 x 8 x 6	

For use with gas fired appliances producing flue gases 90°C or less.



Pipe and Fittings submitted for approval.

<input type="checkbox"/>	197510	1-1/2		
<input type="checkbox"/>	197511	2		
<input type="checkbox"/>	197512	3	CPVC – FGV Access Tee h x H x FPT	
<input type="checkbox"/>	197513	4		
<input type="checkbox"/>	197026	2		
<input type="checkbox"/>	197027	3	CPVC – FGV Coupling H x H	
<input type="checkbox"/>	197023	4		
<input type="checkbox"/>	197137	2		
<input type="checkbox"/>	197138	2-1/2	CPVC – Deep Socket Coupling H x H	
<input type="checkbox"/>	197139	3		
<input type="checkbox"/>	197140	4		
<input type="checkbox"/>	197141	6	CPVC Large Diameter – FGV Coupling H x H	
<input type="checkbox"/>	197142	8		
<input type="checkbox"/>	197470	3 x 2	CPVC – FGV Increaser Coupling H x H	
<input type="checkbox"/>	197472	4 x 2		
<input type="checkbox"/>	196216	2		
<input type="checkbox"/>	196218	2-1/2	FGV Faceplate - Rectangular (white w/ self sealing foam back)	
<input type="checkbox"/>	196219	3		
<input type="checkbox"/>	196050	2		
<input type="checkbox"/>	196051	3	Termination Vent Screens - Polyethylene	
<input type="checkbox"/>	196052	4		
<input type="checkbox"/>	196090	6	Termination Vent Screens - Stainless Steel	
<input type="checkbox"/>	196091	8		
<input type="checkbox"/>	196246	1-1/2 to 4 pipe	Deburring Tool (DEB 4)	
<input type="checkbox"/>	196247	1-1/2 to 3	Cutter	
<input type="checkbox"/>	196046	pint		
<input type="checkbox"/>	196047	quart	CPVC Cement (certified for transitions to PVC)	
<input type="checkbox"/>	196015	gallon		
<input type="checkbox"/>	196044	pint	Transition Cement (for trnsitions to ABS only)	
<input type="checkbox"/>	196042	pint (purple)		
<input type="checkbox"/>	196017	pint (clear)	PVC / CPVC Primer	Primer shall be used when installing System 636™ PVC or CPVC products at temperatures below 0°C.
<input type="checkbox"/>	196043	quart (purple)		
<input type="checkbox"/>	074456	gallon	Swab	

For use with gas fired appliances producing flue gases 90°C or less.

