


## ECLIPSE NO. #88 SAMPLING STATION



• - BY OTHERS

Sampling Stations shall be ' bury, with a 3/4" FIP inlet, and a (3/4" hose or unthreaded) nozzle.


All stations shall be enclosed in a lockable, nonremovable, aluminum-cast housing.

When opened, the station shall require no key for operation, and the water will flow in an all brass waterway.

All working parts will also be of brass and be removable from above ground with no digging. Exterior piping shall be brass or galvanized.

A copper vent tube will enable each station to be pumped free of standing water to prevent freezing and to minimize bacteria growth.

Eclipse No. #88 Sampling Station shall be manufactured by Kupferle Foundry, St. Louis, MO 63102.

		DRAWN F.M. APPROVED		 <b>KUPFERLE FOUNDRY COMPANY</b> 2511 NORTH 9TH STREET, ST. LOUIS, MO 63102 314-231-8738 800-231-3880 FAX 314-231-2820 <a href="http://www.hydrants.com">http://www.hydrants.com</a>
		DATE 11-07-12 MAT'L		
		THIS DRAWING IS THE PROPERTY OF THE KUPFERLE FOUNDRY COMPANY. IT IS NOT TO BE USED OR DUPLICATED WITHOUT PERMISSION OF THE OWNER.		
		PART NO. #88 SAMPLING STATION		
DATE	REVISION	SHEET 1 OF 1		